

# Confirmation

## LEED

On 14/07/2016, Eurofins Product Testing A/S received a sample of a Primer with the product name:

### **NoEM ELECTRO PROTECTOR**

supplied by

### **Selena FM S.A.**

The sample was supplied as being representative of the manufactured product, and it has been tested as a primer in accordance with the relevant ISO 16000, AgBB, ISO 11890-2 and ASTM D6886 testing standards (See test report no. 392-2016-00278801\_A\_EN and 392-2016-00330201\_XG\_EN).

**The test results of the tested coating indicate that the product qualifies for LEED v4 specifications on VOC emissions and/or VOC content by complying with:**


**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of DIBt (October 2010) and AgBB (February 2015), and the formaldehyde limit of 10 µg/m<sup>3</sup> after 28 days

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- the requirements of SCAQMD rule 1113 (2011)
- the requirements of the EU Decopaint Directive 2004/42/CE

5 October 2016



Thomas Bjerring  
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.